

Numar/ Eticheta	$\Phi_{T,e}$	Φ_T	$\Phi_{V,min}$	$\Phi_{V,inf}$	$\Phi_{V,su}$	$\Phi_{V,m,inf}$	Φ_{Net}	Φ_{RH}	Φ_{red}
Apartamentul: 5									
5P01/Hol 20.0 °C 13.2 m ² 39.7 m ³	412	370	236	37.8	0	0	607		512
5P02/Camera de zi 22.0 °C 50.2 m ² 150.5 m ³	2671	2831	947	227	0	0	3777		3023
5P03/CT 12.8 °C 2.2 m ² 6.5 m ³			0	4.96	0	0			
5P04/WC 20.0 °C 4.4 m ² 13.1 m ³	332	357	233	12.4	0	0	590		488
Apartamentul: 6									
6P01/Hol 20.0 °C 13.2 m ² 39.7 m ³	412	370	236	37.8	0	0	606		512
6P02/Camera de zi 22.0 °C 50.2 m ² 150.5 m ³	2670	2830	947	227	0	0	3777		3023
6P03/CT 12.8 °C 2.2 m ² 6.5 m ³			0	4.95	0	0			
6P04/WC 20.0 °C 4.4 m ² 13.1 m ³	332	357	233	12.4	0	0	590		488
Nivel P 135.5 m ² 406.6 m ³	6829		2833	555	0	0			

Numar/ Eticheta	$\Phi_{T,e}$	Φ_T	$\Phi_{V,min}$	$\Phi_{V,inf}$	$\Phi_{V,su}$	$\Phi_{V,m,inf}$	Φ_{Net}	Φ_{RH}	Φ_{red}
Apartamentul: 5									
5E01/Hol 20.0 °C 15.5 m ² 40.2 m ³	313	244	239	38.3	0	0	483		483
5E02/Baie cu cada 24.0 °C 5.0 m ² 13.1 m ³	60	170	261	0	0	0	431		425
5E03/Dormitor 22.0 °C 17.7 m ² 46.0 m ³	852	872	289	69.4	0	0	1161		1161
5E04/Dormitor 22.0 °C 12.9 m ² 33.7 m ³	584	595	212	33.9	0	0	806		805
5E05/Dormitor 22.0 °C 12.9 m ² 33.6 m ³	642	641	212	33.8	0	0	853		838
5E06/Baie cu cada 24.0 °C 3.9 m ² 10.1 m ³	249	325	200	10.7	0	0	525		468
Apartamentul: 6									
6E01/Hol 20.0 °C 15.5 m ² 40.2 m ³	313	244	239	38.3	0	0	483		483
6E02/Baie cu cada 24.0 °C 5.0 m ² 13.1 m ³	60	170	261	0	0	0	431		425
6E03/Dormitor 22.0 °C 17.7 m ² 46.0 m ³	850	870	289	69.4	0	0	1159		1159
6E04/Dormitor 22.0 °C 13.0 m ² 33.7 m ³	584	595	212	33.9	0	0	807		806
6E05/Dormitor 22.0 °C 12.9 m ² 33.6 m ³	641	641	212	33.9	0	0	852		838
6E06/Baie cu cada 24.0 °C 3.9 m ² 10.1 m ³	249	325	200	10.7	0	0	525		468
Nivel E 135.9 m ² 353.4 m ³	5397		2826	372	0	0			

Cladire	12226		5659	927	0	0			---