

--	--

Parametri camerei	Data: 2009
--------------------------	-------------------

Etaj/Apart	Numar/ Eticheta	Temp. incaperii °C	Nr. minim de sch. orare prin ventilatie 1/h	Timpul initial de incalzire h
P/5	5P01 / Hol	20.0	0.5	
P/5	5P02 / Camera de zi	22.0	0.5	
P/5	5P03 / CT	12.8 (neincalzita)		
P/5	5P04 / WC	20.0	1.5	
P/6	6P01 / Hol	20.0	0.5	
P/6	6P02 / Camera de zi	22.0	0.5	
P/6	6P03 / CT	12.8 (neincalzita)		
P/6	6P04 / WC	20.0	1.5	

Etaj/Apart	Numar/ Eticheta	Temp. incaperii °C	Nr. minim de sch. orare prin ventilatie 1/h	Timpul initial de incalzire h
E/5	5E01 / Hol	20.0	0.5	
E/5	5E02 / Baie cu cada	24.0	1.5	
E/5	5E03 / Dormitor	22.0	0.5	
E/5	5E04 / Dormitor	22.0	0.5	
E/5	5E05 / Dormitor	22.0	0.5	
E/5	5E06 / Baie cu cada	24.0	1.5	
E/6	6E01 / Hol	20.0	0.5	
E/6	6E02 / Baie cu cada	24.0	1.5	
E/6	6E03 / Dormitor	22.0	0.5	
E/6	6E04 / Dormitor	22.0	0.5	
E/6	6E05 / Dormitor	22.0	0.5	
E/6	6E06 / Baie cu cada	24.0	1.5	